

SOUTHWESTERN PENNSYLVANIA WATER AUTHORITY
1442 JEFFERSON ROAD
P.O. BOX 187
JEFFERSON, PA 15344
724-883-2301/724-627-7445/800-356-4168

INTERIOR METER SERVICE LINE SPECIFICATIONS

1. SERVICE LINES FROM CURB STOP TO METER MUST BE A MINIMUM OF 3/4" TYPE K COPPER TUBING.
2. SERVICE LINES SHALL BE BURIED AT A MINIMUM DEPTH OF NO LESS THAN 36".
3. DISTANCE FROM CURB STOP TO WATER METER SHALL BE NO MORE THAN 300' IN LENGTH, AND MAY USE ONLY TWO (2) 3/4" COMPRESSION UNIONS, BEING A FORD C-44-33-Q, MUELLER H-15403, OR A MCDONALD 4758-Q.
4. ALL FITTINGS BEFORE THE WATER METER SHALL BE COMPRESSION.
5. SERVICE LINES MUST BE INSPECTED BY SOUTHWESTERN PENNSYLVANIA WATER AUTHORITY PERSONNEL BEFORE BACKFILLING.
6. SERVICE LINE INSPECTIONS WILL BE DONE BETWEEN THE HOURS OF 8:30 A.M. TO 3:00 P.M. MONDAY THROUGH FRIDAY – NO EXCEPTIONS.
7. A DUAL CHECK BACKFLOW PREVENTOR IS ALSO REQUIRED. WE ALSO RECOMMEND INSTALLING A SMALL EXPANSION TANK TO AVOID HOT WATER TANK POP OFF VALVES FROM OPENING.

NOTE: ANY OTHER QUESTIONS REGARDING THE INTERIOR METER INSTALLATION SHALL BE DIRECTED TO SOUTHWESTERN PENNSYLVANIA WATER AUTHORITY AT THE ABOVE PHONE NUMBERS.

TYPICAL INTERIOR METER INSTALLATION

